

Cincinnati Central School District - 2024 Lead Testing Results

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
W1 (ELEMENTARY OFFICE)	9/28/2024 06:02	10/14/2024 13:01	70316030001	Lead	14.5	5	ug/L
W2A (100)	9/28/2024 06:03	10/14/2024 13:08	70316030002	Lead	4.0	5	ug/L
W2B (100DF)	9/28/2024 06:03	10/14/2024 13:13	70316030003	Lead	4.6	5	ug/L
W3A (101)	9/28/2024 06:05	10/14/2024 13:17	70316030004	Lead	3.5	5	ug/L
W3B (101DF)	9/28/2024 06:05	10/14/2024 13:19	70316030005	Lead	4.6	5	ug/L
W4A (102)	9/28/2024 06:06	10/14/2024 13:21	70316030006	Lead	7.9	5	ug/L
W4B (102DF)	9/28/2024 06:06	10/14/2024 13:22	70316030007	Lead	4.7	5	ug/L
W4C (102)	9/28/2024 06:06	10/14/2024 13:24	70316030008	Lead	7.8	5	ug/L
W5A (103)	9/28/2024 06:09	10/14/2024 13:25	70316030009	Lead	2.1	5	ug/L
W5B (103DF)	9/28/2024 06:09	10/14/2024 13:27	70316030010	Lead	<1.0	5	ug/L
W5C (103)	9/28/2024 06:09	10/14/2024 13:29	70316030011	Lead	1.9	5	ug/L
W5D (103) BACK SINK	9/28/2024 06:09	10/14/2024 13:30	70316030012	Lead	16.2	5	ug/L
W6A (104)	9/28/2024 06:09	10/14/2024 13:32	70316030013	Lead	1.9	5	ug/L
W6B (104) DF	9/28/2024 06:11	10/14/2024 13:37	70316030014	Lead	4.6	5	ug/L
W6C (104)	9/28/2024 06:11	10/14/2024 13:38	70316030015	Lead	8.8	5	ug/L
W7A (105)	9/28/2024 06:11	10/14/2024 13:40	70316030016	Lead	2.9	5	ug/L
W7B (105DF)	9/28/2024 06:11	10/14/2024 13:42	70316030017	Lead	4.6	5	ug/L
W8A (106)	9/28/2024 06:14	10/14/2024 13:43	70316030018	Lead	2.6	5	ug/L
W8B (106DF)	9/28/2024 06:14	10/14/2024 13:45	70316030019	Lead	14.0	5	ug/L
W9A (107)	9/28/2024 06:15	10/14/2024 13:46	70316030020	Lead	5.3	5	ug/L
W9B (107DF)	9/28/2024 06:15	10/14/2024 13:51	70316030021	Lead	6.2	5	ug/L
W10A (108)	9/28/2024 06:16	10/14/2024 13:59	70316030022	Lead	4.4	5	ug/L
W10B (108DF)	9/28/2024 06:16	10/14/2024 14:04	70316030023	Lead	4.5	5	ug/L
W11A (115)	9/28/2024 06:21	10/14/2024 14:06	70316030024	Lead	7.2	5	ug/L
W11B (115DF)	9/28/2024 06:21	10/14/2024 14:07	70316030025	Lead	3.4	5	ug/L
W12 (115 116 BATHROOM)	9/28/2024 06:21	10/14/2024 14:09	70316030026	Lead	4.3	5	ug/L
W13A (116)	9/28/2024 06:22	10/14/2024 14:10	70316030027	Lead	6.6	5	ug/L
W13B (116DF)	9/28/2024 06:22	10/14/2024 14:15	70316030028	Lead	2.5	5	ug/L
W14A (120)	9/28/2024 06:24	10/14/2024 14:17	70316030029	Lead	7.8	5	ug/L
W14B (120DF)	9/28/2024 06:24	10/14/2024 14:18	70316030030	Lead	3.4	5	ug/L
W15 (119/120 BATHROOM)	9/28/2024 06:24	10/14/2024 14:20	70316030031	Lead	7.9	5	ug/L
W16A (119)	9/28/2024 06:26	10/14/2024 14:21	70316030032	Lead	10.2	5	ug/L
W16B (119DF)	9/28/2024 06:26	10/14/2024 14:23	70316030033	Lead	2.4	5	ug/L
W17A (109)	9/28/2024 06:28	10/14/2024 14:25	70316030034	Lead	1.9	5	ug/L
W17B (109DF)	9/28/2024 06:28	10/14/2024 14:26	70316030035	Lead	<1.0	5	ug/L
W17C (109)	9/28/2024 06:28	10/14/2024 14:28	70316030036	Lead	1.0	5	ug/L
W18 (BATHROOM #3)	9/28/2024 06:29	10/14/2024 14:29	70316030037	Lead	21.7	5	ug/L
W19A (110)	9/28/2024 06:30	10/14/2024 14:34	70316030038	Lead	2.1	5	ug/L
W19B (110DF)	9/28/2024 06:30	10/14/2024 14:36	70316030039	Lead	4.4	5	ug/L
W19C (110)	9/28/2024 06:30	10/14/2024 14:37	70316030040	Lead	<1.0	5	ug/L
W19D (110 BACK SINK)	9/28/2024 06:30	10/14/2024 14:42	70316030041	Lead	10.2	5	ug/L
W20A (111)	9/28/2024 06:33	10/14/2024 14:47	70316030042	Lead	14.1	5	ug/L
W20B (111DF)	9/28/2024 06:33	10/14/2024 14:55	70316030043	Lead	8.1	5	ug/L
W20C (111)	9/28/2024 06:33	10/14/2024 14:56	70316030044	Lead	11.5	5	ug/L
W21A (112)	9/28/2024 06:34	10/14/2024 14:58	70316030045	Lead	3.8	5	ug/L
W21B (112DF)	9/28/2024 06:34	10/14/2024 14:59	70316030046	Lead	5.8	5	ug/L
W22 (200)	9/28/2024 06:35	10/14/2024 15:01	70316030047	Lead	10.7	5	ug/L
W23 (BATHROOM 2M)	9/28/2024 06:37	10/14/2024 15:03	70316030048	Lead	3.5	5	ug/L
W24 (DF)	9/28/2024 06:38	10/14/2024 15:04	70316030049	Lead	1.2	5	ug/L

W24A (DF BOTTLE FILL)	9/28/2024 06:38	10/14/2024 15:06	70316030050	Lead	<1.0	5	ug/L
W25 (BATHROOM 1W)	9/28/2024 06:39	10/14/2024 15:07	70316030051	Lead	<1.0	5	ug/L
W26	9/28/2024 06:39	10/14/2024 15:12	70316030052	Lead	3.9	5	ug/L
W27A (DF CAFE) LT	9/28/2024 06:42	10/14/2024 15:14	70316030053	Lead	<1.0	5	ug/L
W27B (DF CAFE) RT	9/28/2024 06:42	10/14/2024 15:15	70316030054	Lead	<1.0	5	ug/L
W27C (BOTTLE FILL)	9/28/2024 06:42	10/14/2024 15:17	70316030055	Lead	<1.0	5	ug/L
W28A (SWINGLINE LT)	9/28/2024 06:44	10/14/2024 15:18	70316030056	Lead	9.7	5	ug/L
W28B (SWINGLINE RT)	9/28/2024 06:44	10/14/2024 15:20	70316030057	Lead	5.6	5	ug/L
W29A (DSIH WASHER)	9/28/2024 06:49	10/14/2024 15:22	70316030058	Lead	7.8	5	ug/L
W29B (WASH SINK)	9/28/2024 06:49	10/14/2024 15:23	70316030059	Lead	8.4	5	ug/L
W29C	9/28/2024 06:49	10/14/2024 15:25	70316030060	Lead	18.6	5	ug/L
W29D	9/28/2024 06:49	10/14/2024 15:33	70316030061	Lead	4.5	5	ug/L
W29E	9/28/2024 06:49	10/14/2024 15:37	70316030062	Lead	7.6	5	ug/L
W29F	9/28/2024 06:49	10/14/2024 15:42	70316030063	Lead	13.2	5	ug/L
W29G	9/28/2024 06:49	10/14/2024 15:44	70316030064	Lead	1.8	5	ug/L
W29H	9/28/2024 06:49	10/14/2024 15:45	70316030065	Lead	22.9	5	ug/L
W30 (CAFE BATHROOM)	9/28/2024 06:54	10/14/2024 15:50	70316030066	Lead	3.8	5	ug/L
W31 (202)	9/28/2024 06:57	10/14/2024 15:52	70316030067	Lead	4.5	5	ug/L
W32 (4W)	9/28/2024 06:57	10/14/2024 15:53	70316030068	Lead	8.3	5	ug/L
W33 (5M)	9/28/2024 06:58	10/14/2024 15:55	70316030069	Lead	9.9	5	ug/L
W34 (STAFF RM)	9/28/2024 06:59	10/14/2024 15:56	70316030070	Lead	7.0	5	ug/L
W35A (SINK LF)	9/28/2024 07:01	10/14/2024 15:58	70316030071	Lead	11.8	5	ug/L
W35B (DF)	9/28/2024 07:01	10/14/2024 16:00	70316030072	Lead	<1.0	5	ug/L
W35B2 (DF BOTTLE)	9/28/2024 07:01	10/14/2024 16:01	70316030073	Lead	<1.0	5	ug/L
W35C (SINK RT)	9/28/2024 07:01	10/14/2024 16:03	70316030074	Lead	4.7	5	ug/L
W36A (SINK RT)	9/28/2024 07:06	10/14/2024 16:04	70316030075	Lead	6.3	5	ug/L
W36B (DF)	9/28/2024 07:06	10/14/2024 16:09	70316030076	Lead	<1.0	5	ug/L
W36B2 (BOTTLE FILL)	9/28/2024 07:06	10/14/2024 16:11	70316030077	Lead	<1.0	5	ug/L
W36C (SINK RT)	9/28/2024 07:06	10/14/2024 16:12	70316030078	Lead	5.3	5	ug/L
W37 (DF LG GYM)	9/28/2024 07:07	10/14/2024 16:14	70316030079	Lead	<1.0	5	ug/L
W37A (DF BOTTLE)	9/28/2024 07:07	10/14/2024 16:15	70316030080	Lead	<1.0	5	ug/L
W38 (PE #1)	9/28/2024 07:08	10/14/2024 16:20	70316030081	Lead	2.8	5	ug/L
W39 (PE #2)	9/28/2024 07:09	10/14/2024 16:28	70316030082	Lead	4.6	5	ug/L
W40A (BATHROOM 21M) LT	9/28/2024 07:10	10/14/2024 16:33	70316030083	Lead	19.6	5	ug/L
W40B (RIGHT)	9/28/2024 07:10	10/14/2024 16:34	70316030084	Lead	7.0	5	ug/L
W41 (BATHROOM 22HC)	9/28/2024 07:11	10/14/2024 16:36	70316030085	Lead	20.3	5	ug/L
W42A (BATHROOM 23LD) RT	9/28/2024 07:13	10/14/2024 16:38	70316030086	Lead	14.4	5	ug/L
W42B (LEFT)	9/28/2024 07:13	10/14/2024 16:39	70316030087	Lead	9.6	5	ug/L
W43 (DF LEFT)	9/28/2024 07:15	10/14/2024 16:41	70316030088	Lead	<1.0	5	ug/L
W44 (DF RIGHT)	9/28/2024 07:15	10/14/2024 16:42	70316030089	Lead	<1.0	5	ug/L
W44A (BOTTLE FILL)	9/28/2024 07:15	10/14/2024 16:47	70316030090	Lead	<1.0	5	ug/L
W45 (DF) RT	9/28/2024 07:22	10/14/2024 16:49	70316030091	Lead	1.8	5	ug/L
W45A (BOTTLE FILL)	9/28/2024 07:22	10/14/2024 16:50	70316030092	Lead	2.3	5	ug/L
W46 (DF) LT	9/28/2024 07:22	10/14/2024 16:52	70316030093	Lead	3.2	5	ug/L
W47A (BATHROOM 8M) LT	9/28/2024 07:24	10/14/2024 16:53	70316030094	Lead	3.7	5	ug/L
W47B RIGHT	9/28/2024 07:24	10/14/2024 16:55	70316030095	Lead	2.5	5	ug/L
W48 (BATHROOM FHN)	9/28/2024 07:27	10/14/2024 16:57	70316030096	Lead	1.0	5	ug/L
W48A (FHN OFFICE)	9/28/2024 07:27	10/14/2024 16:58	70316030097	Lead	47.3	5	ug/L
W49A (NURSES BATHROOM)	9/28/2024 07:28	10/14/2024 17:00	70316030098	Lead	4.0	5	ug/L
W49B (NURSES EXAM)	9/28/2024 07:28	10/14/2024 17:01	70316030099	Lead	3.7	5	ug/L
W50A (BATHROOM 10W) LT	9/28/2024 07:29	10/14/2024 17:06	70316030100	Lead	7.0	5	ug/L
W50B (BATHROOM 10W) RT	9/28/2024 07:29	10/14/2024 17:11	70316030101	Lead	6.1	5	ug/L
W51 (500)	9/28/2024 07:30	10/14/2024 17:16	70316030102	Lead	12.3	5	ug/L
W52 (CONFRENECE RM)	9/28/2024 07:30	10/14/2024 17:21	70316030103	Lead	2.3	5	ug/L

W53 (BOTTLE FILL)	9/28/2024 07:33	10/14/2024 17:25	70316030104	Lead	<1.0	5	ug/L
W54 (DF)	9/28/2024 07:33	10/14/2024 17:27	70316030105	Lead	<1.0	5	ug/L
W55A (BATHROOM 18+B LT)	9/28/2024 07:34	10/14/2024 17:29	70316030106	Lead	1.1	5	ug/L
W55B (CENTER)	9/28/2024 07:34	10/14/2024 17:30	70316030107	Lead	<1.0	5	ug/L
W55C (RIGHT)	9/28/2024 07:34	10/14/2024 17:32	70316030108	Lead	<1.0	5	ug/L
W56 (222)	9/28/2024 07:36	10/14/2024 17:33	70316030109	Lead	3.3	5	ug/L
W57A (221)	9/28/2024 07:37	10/14/2024 17:35	70316030110	Lead	1.5	5	ug/L
W57B (DF)	9/28/2024 07:37	10/14/2024 17:37	70316030111	Lead	<1.0	5	ug/L
W58A (220)	9/28/2024 07:39	10/14/2024 17:38	70316030112	Lead	1.9	5	ug/L
W58B (DF)	9/28/2024 07:39	10/14/2024 17:40	70316030113	Lead	1.1	5	ug/L
W59A (219)	9/28/2024 07:41	10/14/2024 17:44	70316030114	Lead	1.6	5	ug/L
W59B (DF)	9/28/2024 07:41	10/14/2024 17:46	70316030115	Lead	<1.0	5	ug/L
W60A (213)	9/28/2024 07:43	10/14/2024 17:48	70316030116	Lead	1.4	5	ug/L
W60B (DF)	9/28/2024 07:43	10/14/2024 17:49	70316030117	Lead	<1.0	5	ug/L
W61A (218)	9/28/2024 07:44	10/14/2024 17:51	70316030118	Lead	1.5	5	ug/L
W61B (DF)	9/28/2024 07:44	10/14/2024 17:52	70316030119	Lead	<1.0	5	ug/L
W62A (214)	9/28/2024 07:45	10/14/2024 17:54	70316030120	Lead	2.6	5	ug/L
W62B (DF)	9/28/2024 07:45	10/14/2024 17:59	70316030121	Lead	<1.0	5	ug/L
W63A (217)	9/28/2024 07:46	10/14/2024 18:07	70316030122	Lead	1.7	5	ug/L
W63B (DF)	9/28/2024 07:46	10/14/2024 18:12	70316030123	Lead	<1.0	5	ug/L
W64A (215)	9/28/2024 07:47	10/14/2024 18:13	70316030124	Lead	1.5	5	ug/L
W64B (DF)	9/28/2024 07:47	10/14/2024 18:15	70316030125	Lead	<1.0	5	ug/L
W65A (216)	9/28/2024 07:48	10/14/2024 18:16	70316030126	Lead	1.7	5	ug/L
W65B (DF)	9/28/2024 07:48	10/14/2024 18:18	70316030127	Lead	<1.0	5	ug/L
W66A (226)	9/28/2024 07:49	10/14/2024 18:23	70316030128	Lead	4.3	5	ug/L
W66B (DF)	9/28/2024 07:49	10/14/2024 18:24	70316030129	Lead	3.1	5	ug/L
W67A (230) LT	9/28/2024 07:50	10/14/2024 18:26	70316030130	Lead	47.3	5	ug/L
W67B (230) RT	9/28/2024 07:50	10/14/2024 18:28	70316030131	Lead	34.2	5	ug/L
W68A (BATHROOM #6)	9/28/2024 07:52	10/14/2024 18:29	70316030132	Lead	6.6	5	ug/L
W68B (DF)	9/28/2024 07:52	10/14/2024 18:31	70316030133	Lead	7.5	5	ug/L
W69 (H/S OFFICE 326)	9/28/2024 08:00	10/14/2024 18:32	70316030134	Lead	19.1	5	ug/L
W70 (306 BATHROOM)	9/28/2024 08:02	10/14/2024 18:34	70316030135	Lead	78.9	5	ug/L
W71A (BATHROOM #19M) LT	9/28/2024 08:04	10/14/2024 18:36	70316030136	Lead	15.0	5	ug/L
W71B RT	9/28/2024 08:04	10/14/2024 18:37	70316030137	Lead	6.1	5	ug/L
W72 (DF GUIDANCE) RT	9/28/2024 08:05	10/14/2024 18:42	70316030138	Lead	3.9	5	ug/L
W73 LT	9/28/2024 08:05	10/14/2024 18:44	70316030139	Lead	3.4	5	ug/L
W73A (BOTTLE FILL)	9/28/2024 08:05	10/14/2024 18:45	70316030140	Lead	4.2	5	ug/L
W75A LT BATHROOM #18W	9/28/2024 08:07	10/14/2024 18:50	70316030141	Lead	6.3	5	ug/L
W75B CENTER	9/28/2024 08:07	10/14/2024 18:55	70316030142	Lead	4.5	5	ug/L
W75C RIGHT	9/28/2024 08:07	10/14/2024 19:03	70316030143	Lead	4.4	5	ug/L
W76 (DF)	9/28/2024 08:11	10/14/2024 19:04	70316030144	Lead	2.1	5	ug/L
W76A (BOTTLE FILL)	9/28/2024 08:11	10/14/2024 19:06	70316030145	Lead	2.4	5	ug/L
W77 (BOTTLE FILL)	9/28/2024 08:14	10/14/2024 19:07	70316030146	Lead	<1.0	5	ug/L
W78 (DF)	9/28/2024 08:14	10/14/2024 19:09	70316030147	Lead	<1.0	5	ug/L
W79 (14W)	9/28/2024 08:15	10/14/2024 19:11	70316030148	Lead	3.7	5	ug/L
W80 (15M)	9/28/2024 08:15	10/14/2024 19:12	70316030149	Lead	1.8	5	ug/L
W81A (BATHROOM 16+17) RT	9/28/2024 08:17	10/14/2024 19:14	70316030150	Lead	2.5	5	ug/L
W81B CENTER	9/28/2024 08:17	10/14/2024 19:15	70316030151	Lead	2.4	5	ug/L
W81C LT	9/28/2024 08:17	10/14/2024 19:20	70316030152	Lead	1.2	5	ug/L
W82A (321)	9/28/2024 08:19	10/14/2024 19:22	70316030153	Lead	1.7	5	ug/L
W82B	9/28/2024 08:19	10/14/2024 19:23	70316030154	Lead	1.5	5	ug/L
W83 (320)	9/28/2024 08:21	10/14/2024 19:25	70316030155	Lead	5.6	5	ug/L
W84 (319.1)	9/28/2024 08:48	10/14/2024 19:27	70316030156	Lead	6.2	5	ug/L
W85A	9/28/2024 08:49	10/14/2024 19:28	70316030157	Lead	18.9	5	ug/L

W85B	9/28/2024 08:49	10/14/2024 19:30	70316030158	Lead	20.8	5	ug/L
W85C	9/28/2024 08:49	10/14/2024 19:31	70316030159	Lead	8.3	5	ug/L
W85D (319)	9/28/2024 08:50	10/14/2024 19:33	70316030160	Lead	17.7	5	ug/L
W85E	9/28/2024 08:50	10/14/2024 19:41	70316030161	Lead	7.0	5	ug/L
W85F	9/28/2024 08:50	10/14/2024 19:46	70316030162	Lead	12.4	5	ug/L
W85H	9/28/2024 08:51	10/14/2024 19:51	70316030163	Lead	145	5	ug/L
W85I	9/28/2024 08:51	10/14/2024 19:52	70316030164	Lead	56.5	5	ug/L
W85J	9/28/2024 08:51	10/14/2024 19:54	70316030165	Lead	285	5	ug/L
W85K	9/28/2024 08:51	10/14/2024 19:58	70316030166	Lead	1.4	5	ug/L
W86 (313 CHECM STORAGE)	9/28/2024 08:52	10/14/2024 20:00	70316030167	Lead	2.9	5	ug/L
W87A (313 BACK WALL)	9/28/2024 08:56	10/14/2024 20:02	70316030168	Lead	1.8	5	ug/L
W87B (TEACHERS DESK)	9/28/2024 08:56	10/14/2024 20:03	70316030169	Lead	18.1	5	ug/L
W87C (313)	9/28/2024 08:57	10/14/2024 20:05	70316030170	Lead	10.4	5	ug/L
W87D	9/28/2024 08:57	10/14/2024 20:07	70316030171	Lead	13.1	5	ug/L
W87E	9/28/2024 08:57	10/14/2024 20:08	70316030172	Lead	6.9	5	ug/L
W87F	9/28/2024 08:57	10/14/2024 20:10	70316030173	Lead	10.9	5	ug/L
W87G	9/28/2024 08:57	10/14/2024 20:11	70316030174	Lead	11.5	5	ug/L
W87H	9/28/2024 08:57	10/14/2024 20:13	70316030175	Lead	1.9	5	ug/L
W88 (313/314 WASHROOM)	9/28/2024 09:00	10/14/2024 20:18	70316030176	Lead	2.0	5	ug/L
W89A (314 TEACHERS DESK)	9/28/2024 09:01	10/14/2024 20:19	70316030177	Lead	22.0	5	ug/L
W89B	9/28/2024 09:01	10/14/2024 20:21	70316030178	Lead	8.5	5	ug/L
W89C	9/28/2024 09:01	10/14/2024 20:22	70316030179	Lead	14.3	5	ug/L
W89D 314	9/28/2024 09:02	10/14/2024 20:24	70316030180	Lead	7.5	5	ug/L
W89E	9/28/2024 09:02	10/14/2024 13:04	70316030181	Lead	7.7	5	ug/L
W89G	9/28/2024 09:02	10/14/2024 13:08	70316030182	Lead	2.1	5	ug/L
W89H	9/28/2024 09:02	10/14/2024 13:16	70316030183	Lead	2.7	5	ug/L
W89I	9/28/2024 09:03	10/14/2024 13:17	70316030184	Lead	1.8	5	ug/L
W89J	9/28/2024 09:03	10/14/2024 13:19	70316030185	Lead	2.6	5	ug/L
W89K	9/28/2024 09:03	10/14/2024 13:20	70316030186	Lead	4.1	5	ug/L
W90A (329)	9/28/2024 09:06	10/14/2024 13:22	70316030187	Lead	4.8	5	ug/L
W90B (DF329)	9/28/2024 09:06	10/14/2024 13:23	70316030188	Lead	5.0	5	ug/L
WM (MAIN FROM BUILDING)	9/28/2024 05:48	10/14/2024 13:25	70316030189	Lead	22.6	5	ug/L
W111 (CAFE ICE MACHINE)	9/28/2024 09:08	10/11/2024 14:28	70316030190	Lead	1.8	5	ug/L
W112 (LG GYM ICE MACHINE)	9/28/2024 09:10	10/17/2024 13:54	70316030191	Lead	1.7	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb